

## MST-0420

MWA Air Conditioner Control Box

### Test: Electrical Safety

---

Serial number: 001

---

Tester: C.D.

---

Date: 7/12/2010

---

### Jig details

Use the Megger tester and Appliance tester to perform mains safety checks.

- MWA JIG-003 - Megger Tester
- MWA JIG-009 - Appliance Tester

---

### Test procedure

1. Visually:
  - Check wiring. *PASS*
2. Confirm:
  - Earth continuity to case. *PASS*
3. Perform earth leakage test using the Megger tester on mains level wiring:
  - Safe to proceed if successful. *PASS*
4. Use appliance tester on mains connection and verify safety:
  - Safe to proceed if successful. *PASS*
5. Photograph and upload pictures of all wiring.
  - Documented wiring. *DONE*

---

### Comments